

ANALYTICAL REPORT

Eurofins Edison
777 New Durham Road
Edison, NJ 08817
Tel: (732)549-3900

Laboratory Job ID: 460-250539-1
Client Project/Site: Preschool (22A0019)

For:
WATER Works Laboratory Inc
360 Glenwood Ave
East Orange, New Jersey 07017

Attn: Ms. Camille Retana



Authorized for release by:
1/26/2022 8:09:23 AM

Julie Gilmore, Project Manager I
(484)685-0865
Julie.Gilmore@Eurofinset.com

LINKS

Review your project
results through
TotalAccess

Have a Question?



Visit us at:
www.eurofinsus.com/Env

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Case Narrative

Client: WATER Works Laboratory Inc
Project/Site: Preschool (22A0019)

Job ID: 460-250539-1

- 1
- 2
- 3
- 4
- 5
- 6
- 7

Job ID: 460-250539-1

Laboratory: Eurofins Edison

Narrative

Job Narrative
460-250539-1

Comments

No additional comments.

Receipt

The samples were received on 1/11/2022 11:45 AM. Unless otherwise noted below, the samples arrived in good condition, and where required, properly preserved and on ice. The temperature of the cooler at receipt was 3.1° C.

Metals

No analytical or quality issues were noted, other than those described in the Definitions/Glossary page.

Sample Summary

Client: WATER Works Laboratory Inc
Project/Site: Preschool (22A0019)

Job ID: 460-250539-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
460-250539-1	22A0019-01 (1)	Water	01/10/22 07:00	01/11/22 11:45
460-250539-2	22A0019-02 (2)	Water	01/10/22 07:00	01/11/22 11:45
460-250539-3	22A0019-03 (4)	Water	01/10/22 07:00	01/11/22 11:45

- 1
- 2
- 3
- 4
- 5
- 6
- 7

Client Sample Results

Client: WATER Works Laboratory Inc
Project/Site: Preschool (22A0019)

Job ID: 460-250539-1

Client Sample ID: 22A0019-01 (1)

Date Collected: 01/10/22 07:00

Date Received: 01/11/22 11:45

Lab Sample ID: 460-250539-1

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.11	U	2.0	0.11	ug/L		01/21/22 21:11	1	DLE
Copper	6.4		2.5	0.26	ug/L		01/21/22 21:11	1	DLE

Client Sample ID: 22A0019-02 (2)

Date Collected: 01/10/22 07:00

Date Received: 01/11/22 11:45

Lab Sample ID: 460-250539-2

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.11	U	2.0	0.11	ug/L		01/21/22 21:14	1	DLE
Copper	11.0		2.5	0.26	ug/L		01/21/22 21:14	1	DLE

Client Sample ID: 22A0019-03 (4)

Date Collected: 01/10/22 07:00

Date Received: 01/11/22 11:45

Lab Sample ID: 460-250539-3

Matrix: Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Lead	0.16	J	2.0	0.11	ug/L		01/21/22 21:16	1	DLE
Copper	25.6		2.5	0.26	ug/L		01/21/22 21:16	1	DLE